



4444 Round Lake Road West
 Arden Hills, MN 55112
 651.917.3075
 800.969.0454
 horizonpoolsupply.com

Weekly Log Sheet

Pool Name/Type: _____

Facility: _____

Year: _____



Day/Date	Time of Day	Sanitizer (Br x 2)		pH	Alkalinity	Calcium Hardness	Cyanuric Acid	Temp.	Flow Rate Min=____	Filter Pressure	ORP/HRR	Suc. Cover Secure?	Sanitizer Interlock	CPO Initials
		Free	Combined											
Monday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Tuesday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Wednesday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Thursday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Friday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Saturday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Sunday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													

Ideal Ranges: * Free Chlorine (FAC): 2.0 - 8.0 ppm Total Dissolved Solids (TDS): <2,000 ppm
 Combined Chlorine: <0.5 ppm Alkalinity: 80 - 120 ppm
 Bromine: 4.0 - 12.0 ppm Cyanuric Acid: 0 - 30 ppm
 pH (Phenol Red): 7.4 - 7.5 Calcium Hardness: 150 - 250 ppm (spa) & 200 - 400 ppm (pool)

* These ranges are only guidelines. Pool Operators should always consult local codes for their state and region.



St. Paul & Minneapolis Area Office
651.917.3075
Milwaukee Area Office
262.783.6040

Weekly Log Sheet

Pool Name/Type: _____

Facility: _____

Year: _____



Day/Date	Time of Day	Sanitizer (Br x 2)		pH	Alkalinity	Calcium Hardness	Cyanuric Acid	Temp.	Flow Rate Min=____	Filter Pressure	ORP/HRR	Suc. Cover Secure?	Sanitizer Interlock	CPO Initials
		Free	Combined											
Monday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Tuesday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Wednesday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Thursday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Friday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Saturday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													
Sunday	AM											Y / N	Y / N	
	PM											Y / N	Y / N	
	Notes:													

Ideal Ranges: * Free Chlorine (FAC): 2.0 - 8.0 ppm Total Dissolved Solids (TDS): <2,000 ppm
 Combined Chlorine: <0.5 ppm Alkalinity: 80 - 120 ppm
 Bromine: 4.0 - 12.0 ppm Cyanuric Acid: 0 - 30 ppm
 pH (Phenol Red): 7.4 - 7.5 Calcium Hardness: 150 - 250 ppm (spa) & 200 - 400 ppm (pool)

* These ranges are only guidelines. Pool Operators should always consult local codes for their state and region.